



**Project:** Gripple Hangers  
**Client:** Gripple Ltd  
**Client's Order No:** 3061  
**Inspection Date:**  
**First:** 12/03/2009


**Certificate No:** COV 0919097  
**Office:** Sheffield  
**Date:** 20/02/2009  
**Order Status:** Complete  
**Final:** 12/03/2009

This certificate is issued to Gripple Ltd to certify that the undersigned surveyor did, at their request attend their premises at The Old West Gun Works, Sheffield on and between the above dates for the purpose of examining and witnessing tests on the items listed below. All tests produced satisfactory results.

### TEST CONFIGURATION



M Cobb  
 Surveyor of Lloyd's Register



Gripple Model	Rope Construction	Gripple Rated Load	Gripple Load Limit 5:1	Result		
M10 45° Eyelet No.2	7 x 7 (6/ 1)	10-45 Kg 22-100 lbs	225 Kg 495 lbs	319.9 Kg 703.78 lbs	327.9 Kg 721.38 lbs	365.9 Kg 804.98 lbs
M10 45° Eyelet No.3	7 x 7 (6/ 1)	45-90 Kg 100-200 lbs	450 Kg 990 lbs	686.3 Kg 1503.04 lbs	690.3 Kg 1518.66 lbs	697.0 Kg 1533.4 lbs

**Gripple Ltd** The Old West Gun Works Savile Street East Sheffield S4 7UQ  
 Tel: +44 (0)114 275 2255 Fax: +44 (0)114 275 1155  
 www.gripple.com email: [info@gripple.com](mailto:info@gripple.com)