


Project: GripplE Hangers
Client: GripplE Ltd
Client's Order No: 3061
Inspection Date:
First: 12/03/2009

Certificate No: COV 0919097
Office: Sheffield
Date: 20/02/2009
Order Status: Complete
Final: 12/03/2009

This certificate is issued to GripplE Ltd to certify that the undersigned surveyor did, at their request attend their premises at The Old West Gun Works, Sheffield on and between the above dates for the purpose of examining and witnessing tests on the items listed below. All tests produced satisfactory results.

TEST CONFIGURATION



M Cobb
 Surveyor of Lloyd's Register



GripplE Model	Rope Construction	GripplE Rated Load	GripplE Load Limit 5:1	Result		
				1498.3 kg 3296.3 lbs	1554.5 kg 3412 lbs	1552.2 kg 3415 lbs
No.4 Toggle	7x19 (6/1)	90-225 kg 198-495 lbs	1125kg 2475 lbs	1498.3 kg 3296.3 lbs	1554.5 kg 3412 lbs	1552.2 kg 3415 lbs