


Project: Gripple Hangers
Client: Gripple Ltd
Client's Order No: 3061
Inspection Date:
First: 12/03/2009

Certificate No: COV 0919097
Office: Sheffield
Date: 20/02/2009
Order Status: Complete
Final: 12/03/2009

This certificate is issued to Gripple Ltd to certify that the undersigned surveyor did, at their request attend their premises at The Old West Gun Works, Sheffield on and between the above dates for the purpose of examining and witnessing tests on the items listed below. All tests produced satisfactory results.

TEST CONFIGURATION



4/9/09

M Cobb
 Surveyor of Lloyd's Register

Gripple Model	Rope Construction	Gripple Rated Load	Gripple Load Limit 5:1	Result		
No.1 M6 Barrel	7x7 (6/1)	0 -10 kg	50 kg	96.1 kg	99.8 kg	102.5 kg
		0 – 22 lbs	100 lbs	211.4 lbs	219.56 lbs	265.1 lbs
No.2 M6 Barrel	7x7 (6/1)	10 – 45 kg	225 kg	292.2 kg	248.6 Kg	297.2 Kg
		22 – 100 lbs	495 lbs	642.84 lbs	546.92 lbs	653.84 lbs