


**Project:** Gripple Hangers  
**Client:** Gripple Ltd  
**Client's Order No:** 8624  
**Inspection Date:**  
**First:** 19/12/2007

**Certificate No:** COV 0719796  
**Office:** Sheffield  
**Date:** 19/01/2008  
**Order Status:** Complete  
**Final:** 21/01/2008

This certificate is issued to Gripple Ltd to certify that the undersigned surveyor did, at their request attend their premises at The Old West Gun Works, Sheffield on and between the above dates for the purpose of examining and witnessing tests on the items listed below. All tests produced satisfactory results.

### TEST CONFIGURATION



M Cobb  
 Surveyor of Lloyd's Register

WITNESSED / REVIEWED  
 Lloyd's Register  
 FIMEA  
 Certificate No. 261109

Gripple Model	Rope Construction	Gripple Rated Load	Gripple Load Limit 5:1	Result		
No.2 Eyelet	7x7 (6/1)	10 – 45 kg	225kg	284.3 kg	272.4 kg	265.0 kg
		22 – 100 lbs	500 lbs	625.5 lbs	599.3 lbs	583.0 lbs
No.3 Eyelet	7x7 (6/1)	45 – 90 kg	450 kg	556.4 kg	567.1 kg	566.8 kg
		100 – 200 lbs	990 lbs	1224.1 lbs	1247.6 lbs	1247.0 lbs