


**Project:** GripplE Hangers  
**Client:** GripplE Ltd  
**Client's Order No:** 8624  
**Inspection Date:**  
**First:** 19/12/2007

**Certificate No:** COV 0719796  
**Office:** Sheffield  
**Date:** 19/01/2008  
**Order Status:** Complete  
**Final:** 21/01/2008

This certificate is issued to GripplE Ltd to certify that the undersigned surveyor did, at their request attend their premises at The Old West Gun Works, Sheffield on and between the above dates for the purpose of examining and witnessing tests on the items listed below. All tests produced satisfactory results.

**TEST CONFIGURATION**



M Cobb  
 Surveyor of Lloyd's Register



GripplE Model	Rope Construction	GripplE Rated Load	GripplE Load Limit 5:1	Result		
No.1 Snap Hook	7x7 (6/1)	0 -10 kg 0 - 22 lbs	50kg 110 lbs	95.1kg 209.2 lbs	91.4 kg 201.1 lbs	70.0 kg 154.0 lbs
No.2 Snap Hook	7x7 (6/1)	10 - 45 kg 22 - 100 lbs	225kg 500 lbs	297.6 kg 654.7 lbs	278.4 kg 612.5 lbs	265.3 kg 583.7 lbs
No.3 Snap Hook	7x7 (6/1)	45 - 90 kg 100 - 200 lbs	450 kg 990 lbs	536.9 kg 1181.2 lbs	531.3 kg 1168.9 lbs	528.4 kg 1162.5 lbs